


EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CR0399
 Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräterichtlinie (2009/142/EG)</i>
Distributor <i>Vertreiber</i>	COINTRA GODESIA S.A. Avda. de Italia, 2, E-28820 Coslada - Madrid
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing boiler with fan-assisted burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	SUPERLATIVE...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	type testing: K18382016B2 from 27.10.2016 (TRG) type testing: K18392016T1 from 27.10.2016 (TRG)
Test Basis <i>Prüfgrundlagen</i>	2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.01.2013)
File Number <i>Aktenzeichen</i>	16-0382-GEE



T0028-04-A-DE

01.03.2017 Rie C-1/2 
 Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.



DVGW CERT GmbH
 Zertifizierungsstelle
 Josef-Wirmer-Str. 1-3
 53123 Bonn
 Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993
 www.dvgw-cert.com
 info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz
Elektrische Daten

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2ELw	20 mbar	PL	
II2E+3P	20/25, 30 mbar	BE, FR	
II2E+3P	20/25, 37 mbar	BE, FR	
II2ELL3B/P	20, 50 mbar	DE	
II2H3B/P	20, 30 mbar	CY, DK, EE, FI, HR, IE, IS, IT, LT, NO, RO, SE, SI, SK, TR	
II2H3B/P	20, 37 mbar	GR, IE, LV	
II2H3B/P	20, 50 mbar	AT, CH, CZ, HR, LU	
II2H3P	20, 37 mbar	ES	
II2HS3B/P	25, 30 mbar	HU	
II2HS3B/P	25, 50 mbar	HU	
II2L3B/P	25, 30 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
SUPERLATIVE CONDENS 25C	nominal heat output: 5,7...24,5 kW heat input (Hi): 5,8...25,0 (drinking water: ...27,0) kW	
SUPERLATIVE CONDENS 32C	nominal heat output: 6,6...28,9 kW heat input (Hi): 6,7...29,5 (drinking water: ...32,0) kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

flue types B23, B33, C13(x), C23, C33(x), C43(x), C53(x), C63(x), C83(x): accordint to installation manual
 SUPERLATIVE...

Additional proved countries of destination, appliance categories and supply pressures:

AL, MK: II2E3B/P (20, 50 mbar)

BG, MT: II2H3B/P (20, 30 mbar)

GB: II2H3P (20, 37 mbar) and II2H3B (20, 30 mbar)

PT: II2H3B/P (20, 37 mbar)

NL: II2EK3B/P (25, 30 mbar)

In Albania and Macedonia the CE-marking will be accepted as conformaty approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Albania respectively Macedonia.

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CR0399
 Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Distributor <i>Vertreiber</i>	COINTRA GODESIA S.A. Avda. de Italia, 2, E-28820 Coslada - Madrid
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing boiler with fan-assisted burner in modulating operation method and with enclosed combustion chamber
Model <i>Modell</i>	SUPERLATIVE...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	type testing: K18382016B3 from 27.10.2016 (TRG)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	16-0382-GWE



70205-04-4-DE

01.03.2017 Rie C-1/2



Date, Issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.



Deutsche
 Akkreditierungsstelle
 D-ZE-16028-01-04

DVGW CERT GmbH
 Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
 53123 Bonn

Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993

www.dvgw-cert.com
 info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
SUPERLATIVE CONDENS 25C	nominal heat output: 5,7...24,5 kW heat input (Hi): 5,8...25,0 (drinking water: ...27,0) kW	
SUPERLATIVE CONDENS 32C	nominal heat output: 6,6...28,9 kW heat input (Hi): 6,7...29,5 (drinking water: ...32,0) kW	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

The above listed model was certified under the Product-Identnumber CE-0085CR0399 according to the Gas Appliance Directive (2009/142/EC).